

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 3774-0139:122

Page 1 of 1

**CATEGORY:** Electric Locks

**LISTEE:** Von Duprin, 2720 Tobey Dr., Indianapolis IN 46219  
Contact: Roger Vitt \*(317) 715-4420 Fax (317) 715-4473

**DESIGN:** Models 873-DE, 5200 and DE5101 special locking arrangement. The units are delayed exit control systems which allows exit when power loss occurs or when a fire is detected. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 24 VAC/DC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model designation, electrical rating and UL label.

**APPROVAL:** Listed as electromagnetic door locks for use with swinging type doors as a mean of supplemental locking of the door in addition to the door's required latching mechanism when installed in accordance with the California Building Code, Section 1003.3.1.10 Special egress-control devices. Authority having jurisdiction shall be consulted prior to installation.

\*Rev. 06-13-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 13, 2003**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager